

Chapter 154

PLUMBING

[HISTORY: Adopted by the Special Town Meeting of the Town of Lee 6-22-1978 by Art. 5 (Ch. 13 of the 1971 Code). Amendments noted where applicable.]

§ 154-1. Water use regulations; variance.

- A. Any toilet or water closet installed after the effective date of this chapter shall not use more than 3.5 gallons of water per flush.
- B. Any urinal installed after the effective date of this chapter shall not use more than 1.5 gallons per flush.
- C. Any shower head installed after the effective date of this chapter shall not permit water to be used at a rate in excess of three gallons per minute.
- D. Any kitchen or bathroom sink fixture installed after the effective date of this chapter shall not permit a flow of water in excess of 2.5 gallons per minute.
- E. Variance. The Building Inspector may grant a variance from the above restrictions upon written application and upon good cause shown.