

## Well Setback Reference Sheet

Distances to possible sources of contamination from proposed well:	Required Minimum Lateral Distance
Potential Source of Contamination	
Subsurface Sewage Disposal Field	100 Feet
2. Cesspool or Sewage Pit	150 Feet
3. Septic Tank	50 Feet
4. Sewer Lines (constructed of durable corrosion resistant material with watertight joints)	10 Feet
5. Sewer Lines (constructed of any other type pipe)	50 Feet
6. Property Lines	30 Feet
7. Public Ways	25 Feet
8. Driveways	25 Feet
9. Underground Storage Tanks	200 Feet
Distance to buildings, roads, etc. (if less than 200 feet)	
10. Existing and Proposed Structures:	
Additional Structure:	
11. Subsurface Water and Subsurface Drainage Courses:	
12. Other Reasonably Recognizable Sources of Pollution:	